

# City of Munroe Falls

43 Munroe Falls Avenue, Munroe Falls Ohio 44262  
330-688-7491 phone 330-688-3720 fax



## 2021 Drinking Water Consumer Confidence Report

The City of Munroe Falls Water Department has prepared the following report to provide information to you, the consumer, on the quality of your drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791)**. In 2021 your drinking water met all Ohio EPA standards.

### Source Water Information

The City of Munroe Falls receives its drinking water from the City of Cuyahoga Falls. The Cuyahoga Falls water treatment plant, which is located at 2028 Munroe Falls Avenue, uses well water as a source. The well field consists of 18 wells located in Water Works Park on the south bank of the Cuyahoga River.

The well field, which is the source for raw water to the water treatment plant, is surrounded by two theoretical protection zones. The "inner protection zone" is the area that provides ground water to the City of Cuyahoga Falls' wells within one year of pumping. A chemical spill in this zone poses a greater threat to the drinking water, so this area warrants more stringent protection. The "outer protection zone" is the additional area that contributes water when the well is pumped for five years. An inventory of potential contaminant sources located within the drinking water source was conducted by the Ohio EPA in 2002. Nineteen potential sources of contamination were identified within the protection areas. A list of these potential contaminants is available in the source water assessment report. If you would like more information about this assessment, please contact James Bowery at 330-688-7491.

### Source Water Assessment & Protection

A susceptibility analysis done by the EPA determined that the Cuyahoga Falls source of drinking water has a high susceptibility to contamination.

The protection of groundwater and our drinking water source is the responsibility of all area residents. Please dispose of chemicals, household cleaners and pesticides in the proper manner. For more information contact Summit County **REWORKS** at 330-374-0383 or go to [www.summitreworks.com](http://www.summitreworks.com).

### About Your Drinking Water

The Munroe Falls pumping station, located at 272 Munroe Falls Avenue, pumped an average of 352,000 gallons of water a night in 2021 into two water tanks: a 1.5 million gallon reservoir located behind Sprenger Retirement Center and a 200,000 gallon tower on Gaylord Drive. Although MFWD doesn't treat the water, the City tests for coliform bacteria, chlorine levels, and lead and copper. Of the 72 bacteria samples analyzed in 2020, all showed 0% presence of coliform bacteria.

Under the Stage 2 Disinfectants/Disinfection Byproducts Rule (D/DBPR), our public water system is required by USEPA to conduct an evaluation of our distribution system. This is known as an Initial Distribution System Evaluation (IDSE), and is intended to identify locations in our distribution system with elevated disinfection byproduct concentrations. The locations selected for the IDSE are used for compliance monitoring under Stage 2 DBPR since 2012. Disinfection byproducts are the result of providing continuous disinfection of your drinking water and

form when disinfectants combine with organic matter naturally occurring in the source water. Disinfection byproducts are grouped into two categories, Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5). The USEPA sets standards for controlling the levels of disinfectants and disinfection byproducts in drinking water, including both TTHMs and HAA5s.

### Customer Participation in Decision Making

Residents are encouraged to participate in the decisions about their water made at Munroe Falls bi-weekly City Council meetings held at City Hall on the first and third Tuesday each month at 7:00pm. For further information, call the City Hall at **(330) 688-7491** 8:00 to 4:30 pm Monday through Friday.

### Contact Information

Please contact the Munroe Falls Service Director, **James Bowery**, at **330-688-7491** if you have any questions about this report, the information it contains, or the department's operations. Or, email at [water@munroefalls.com](mailto:water@munroefalls.com).

Sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**The City of Munroe Falls Water Department operated under an unconditioned license to operate during the year 2021. A copy of that license is located at 43 Munroe Falls Avenue, Munroe Falls, Ohio.**

## Monitoring Results for 2021

Contaminant (Units)	MCL	MCLG	Level Detected	Range of Detections	Violation	Year Sampled	Typical Source of Contaminants
<b>Lead and Copper - City of Munroe Falls collects from residential taps once every year beginning 2017</b>							
Lead (ppb) from 20 residential taps	0 out of 20 samples were found to have lead levels in excess of the Action Level of 15ppb						
	AL = 15 (Action level)	0 (goal level)	ND	ND	NO	2021	Corrosion of household plumbing fixtures
Copper (ppm) from 20 residential taps	0 out of the 20 samples were found to have copper levels in excess of the Action Level of 1.3 ppm						
	AL = 1.3 (Action level)	1.3 (goal level)	.67	.008 to .7	NO	2021	Corrosion of household plumbing fixtures
<b>Inorganic Contaminants - these chemicals are tested by City of Cuyahoga Falls</b>							
Fluoride (ppm)	4	4	1.0	0.8 to 1.1	NO	Daily	Water additive that promotes strong teeth.
<b>Disinfection Byproducts - City of Munroe Falls samples locally every 90 days</b>							
Total Trihalomethanes TTHMs (ppb)	80	N/A	65.53	0.00 to 113	NO	2021	By-product of drinking water chlorination.
Haloacetic Acids HAA5 (ppb)	60	N/A	14.98	11.9 to 17	NO	2021	By-product of drinking water chlorination.
<b>Residual Disinfectants - City of Munroe Falls samples daily</b>							
Total Chlorine (ppm)	MRDL=4	MRDLG=4	1.4275	1.26 to 1.48	NO	Daily	Water additive to control microbes

### KEY TO TABLE

ppm is parts per million, or 1 part in a million parts  
ppb is parts per billion, or 1 part in a billion parts  
MCL - Maximum Contaminant Level  
MCLG - Maximum Contaminant Level Goal  
N/A - not applicable

1 ppm is equivalent to 1 inch in 15.78 miles  
1 ppb is equivalent to 1 inch in 15,782 miles  
ND - not detected  
MRDL - Maximum Residual Disinfectant Level  
MRDLG - Maximum Residual Disinfectant Level Goal

**CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:**

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agriculture livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

**Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

**EPA DEFINITIONS**

**Maximum contaminant level goal (MCLG).** *“The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.”*

**Maximum contaminant level (MCL).** *“The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.”*

**Maximum Residual Disinfection Level (MRDL).** *“The highest level of a disinfectant allowed in drinking water.”*

**Maximum Residual Disinfectant Level Goal (MRDLG).** *“The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.”*

**Treatment technique.** *“A required process intended to reduce the level of a contaminant in drinking water.”*

**Action Level (AL)** *“The concentration of a contaminant which, if exceeded, triggers a treatment or other requirement which a water system must follow.”*

**Variance and exemption.** *“State or EPA permission not to meet an MCL or a treatment technique under certain conditions.”*

**PFAS:** *“Per- and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals applied to many industrial, commercial and consumer products to make them water-proof, stain resistant, or nonstick. PFAS are also used in products like cosmetics, fast food packaging, and a type of fire-fighting foam called aqueous film forming foam (AFFF) which are used mainly on large spills of flammable liquids, such as jet fuel. PFAS are classified as contaminants of emerging concern, meaning that research into the harm they may cause to human health is still ongoing.”*

All water systems were required to begin compliance with a new rule, the Revised Total Coliform Rule, on April 1, 2016. The new rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of total coliform bacteria, which includes E.coli bacteria. The U.S. EPA anticipates greater public health protection under the new rule, as it requires water systems that are vulnerable to microbial contamination to identify and fix problems. As a result, under the new rule there is no longer a maximum contaminant level violation for multiple total coliform detections. Instead, the new rule requires water systems that exceed a specified frequency of total coliform occurrences to conduct an assessment to determine if any significant deficiencies exist. If found, these must be corrected by the Public Water System.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.*

एस्ट इन्फॉर्म कन्टिन इन्फोटासियन महत्त्वपूर्ण *acerca de su agua potable. हागा* que alguien lo traduzca para usted, o hable con alguien que lo entienda.

**You are encouraged to share this information with others you think may not have received it, or, due to language or other barrier, may not be able to understand it. Please feel free to contact MUNROE FALLS WATER DEPT or Jim Bowery, Service Director at 330-688-7491 with any questions.**

**Lead in Drinking Water**

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Munroe Falls Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>*

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

**Who should take special precautions**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).